





Certificate: 2016623

Master Contract: 158031

Project: 80207925

Date Issued: 2024-05-08

Temperature Controllers, Model Series EZK followed by B, C, D or E followed by L or H, followed by any letter or number, followed by any two numbers or letters, followed by A, followed by any letter or number, followed by any two letters or numbers. The front panel of these devices are Type 1, Type 4 (Indoor Use Only) approved for indoor use when properly mounted with integrated gasket.

Model(s)	Input Voltage (V)	Frequency	Input Power (VA)
EZK	15 to 36	DC	10VA
	24	50/60Hz	10VA
	100 to 240	50/60Hz/DC	10VA

**APPLICABLE REQUIREMENTS**

CSA C22.2 No. 24-15 (Ninth edition) (R2019) - Temperature-indicating and -regulating equipment

CAN CSA C22.2 No. 0 - General requirements — Canadian Electrical Code, Part II



**Certificate:** 2016623

**Master Contract:** 158031

**Project:** 80207925

**Date Issued:** 2024-05-08

Notes:

Products certified under Class(es) C481302 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). [www.scc.ca](http://www.scc.ca)

